

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3	7.59	160	0.92		Y
4					
5					
6					
7					
8					
9	7.64	160	0.95		Y
10					
11					
12					
13					
14					
15					
16	7.41	160	0.95		Y
17					
18					
19					
20					
21					
22					
23	7.38	160	1.08		Y
24					
25					
26					
27					
28					
29	7.90	180	1.35		Y
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: March - 2023  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<span style="border: 1px solid black; padding: 2px;">7.2</span>	
Alk	<span style="border: 1px solid black; padding: 2px;">99</span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;">0.8</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;">/</span>	( )

Print Name: Patricia Ramos Pino

Signature: *Patricia Ramos Pino*

Date: 4-05-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0