

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.87	180	0.99		Y
3					
4					
5					
6					
7					
8					
9	7.64	180	0.85		Y
10					
11					
12					
13					
14					
15					
16					
17	7.64	180	1.08		Y
18					
19					
20					
21					
22					
23	8.06	160	0.85		Y
24					
25					
26					
27					
28					
29					
30	7.69	160	0.89		Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: May - 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

-For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other		()

Print Name: Patricio Ramos Pino

Signature: *Patricio Ramos Pino*

Date: 6-05-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0