

Day	pH	Alk	Phos	Other	Y/N
1				/	
2	7.61	160	0.85		Y
3					
4					
5					
6					
7					
8					
9	7.56	160	0.89		Y
10					
11					
12					
13					
14					
15					
16					
17	7.55	140	0.82		Y
18					
19					
20					
21					
22					
23					
24	7.69	140	0.89		Y
25					
26					
27					
28					
29					
30					
31	7.48	160	0.92		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: August - 2023
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	(_____)

Print Name: Patricia Ramos P.

Signature: *Patricia Ramos*

Date: 9-08-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0