

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4					
5	7.72	120	0.82		Y
6					
7					
8					
9					
10					
11					
12	7.50	140	0.89		Y
13					
14					
15					
16					
17					
18					
19					
20					
21	7.58	120	0.85		Y
22					
23					
24					
25					
26					
27					
28	7.85	140	1.01		Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: September - 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="99"/>	(Alkalinity)
PO4	<input type="text" value="0.8"/>	(Orthophosphate)
Other	<input type="text" value="/"/>	()

Print Name: Patricia Ramos Pino

Signature: *Patricia Ramos Pino*

Date: 10-10-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's