

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				/	
2	7.80	140	0.92		Y
3					
4					
5					
6					
7					
8					
9					
10	7.64	120	1.05		Y
11					
12					
13					
14					
15					
16					
17					
18	7.58	140	1.05		Y
19					
20					
21					
22					
23					
24	7.48	120	1.15		Y
25					
26					
27					
28					
29					
30					
31	7.70	140	0.85		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 1 1 6 7

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: October - 2023
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

-For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	()

Print Name: Patricia Ramos Pino

Signature: [Signature]

Date: 11-08-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0