

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4	7.55	140	0.92		Y
5					
6					
7					
8					
9					
10					
11	7.52	120	0.95		Y
12					
13					
14					
15					
16					
17					
18	7.48	140	0.92		Y
19					
20					
21					
22					
23	7.54	140	0.85		Y
24					
25					
26					
27	7.36	120	0.85		Y
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: December - 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

-For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="99"/>	(Alkalinity)
PO4	<input type="text" value="0.8"/>	(Orthophosphate)
Other	<input type="text" value="/"/>	(_____)

Print Name: Patricio Ramos Pino

Signature: *Patricio Ramos Pino*

Date: 1/09/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's