

Day	pH	Alk	Phos	Other	Y/N
1				/	
2	7.53	140	0.82		Y
3					
4					
5					
6					
7					
8					
9	7.64	140	0.82		Y
10					
11					
12					
13					
14					
15					
16	7.68	140	0.85		Y
17					
18					
19					
20					
21	7.67	140	0.82		Y
22					
23					
24					
25					
26					
27					
28	7.58	140	0.82		Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: March - 2024
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>99</u>	(Alkalinity)
PO4	<u>0.8</u>	(Orthophosphate)
Other	/	()

Print Name: Patricia Ramos Pino

Signature: 

Date: 4-10-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0