

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | рН | Alk | Phos | Other | Y/N | < <have entry="" point<="" th=""></have> |
|------|----------|--------|---------------|--------------|--------------|--|
| 1 | | | | | | minimuins been met for |
| 2 | | | | | | this day? PWS ID: 41 41 41 |
| 3 | 7,50 | 140 | 0.85 | | Y | System Name: Mt. Hood Meadows Spring |
| 4 | | | | | | Entry Point: A |
| 5 | | | | | | Sample Period: April - 2024 |
| 6 | | | | | | Month/Year |
| 7 | | | | | | Number of excursions* during this month: 0 |
| 8 | | | | | | (Count the number of days when any WQP was |
| 9 | | | | | | less than the minimum required) |
| 10 | | | | | .,, | Jess than the milliman requires, |
| 11 | 7.66 | 140 | 0.92 | | 14 | Total excursions during the previous 5 months: 0 |
| 12 | | | | - | - | (Over 9 excursions in 6 months is a violation. Entry |
| 13 | | | | ļ | - | Point and Distribution excursions are cumulative) |
| 14 | <u> </u> | | | | | ' |
| 15 | <u> </u> | | | | - | _[-For OHA use only |
| 16 | ļ | | - | ļ | | 104 A - v Occolitus |
| 17 | | 1110 | 1000 | | V | Minimum Water Quality |
| 18 | 7.62 | 140 | 0.92 | - | 1 | Parameters as set by |
| 19 | | - | | | | pH 7.2 |
| 20 | <u> </u> | | | | - | Alk 99 (Alkalinity) |
| 21 | | ļ | | | - | PO4 0.8 (Orthophosphate) |
| 22 | <u> </u> | | | | | Other () |
| 23 | | | | | | |
| 24 | ļ | | | | | |
| 25 | | 11.0 | 0.00 | | N/ | |
| 26 | 7.70 | 140 | 0.92 | - | 1 | 24.20.20. |
| 27 | | ļ | | ļ | ļ | Print Name: Patricio Hamas Pino |
| 28 | | | | | | Signature: |
| 29 | | | | | - | Date: 05 6 04-2824 |
| 30 | | ļ | | | | Send to DWP within 10 days after end of |
| 31 | | | | | | sampling period |
| No = | N = Ex | cursio | n) Tot | al N's | 0 | A4050 Bortland OR 97293-0350 |

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/