

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1				/		minimums been met for
2						this day? PWS ID: 41 9 1 6 7
3						System Name: Mt. Hood Meadows Spring
4	7.69	140	0.85		Y	Entry Point: A
5						Sample Period: MAY - 2024
6						Month/Year
7					-	Number of excursions* during this month: 0
8						(Count the number of days when any WQP was
9	7/1	140	0.85		7	less than the minimum required)
11	7.61	140	UNOS			, ,
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative)
15						For OHA use only
16						, or or in age only
17	7.75	140	0.89		Y	Minimum Water Quality
18						Parameters as set by
19						pH 7.2
20						Alk 99 (Alkalinity)
21						PO4 0.8 (Orthophosphate)
22	707	11. Δ	0.00		U _a	Other (
23 24	7.87	140	0.85			
25						
26	.*					
27						Print Name: Patricio Ramas Pino
28	7.88	140	0.82		Y	
29	1.00		0.00			Signature: Jalum Jamf Date: 6-06-2024
30						
31						Send to DWP within 10 days after end of sampling period
lo = N = Excursion) Total N's						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/