

| Day | pH   | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1   |      |     |      | /     |     |
| 2   |      |     |      |       |     |
| 3   | 7.71 | 140 | 0.92 |       | Y   |
| 4   |      |     |      |       |     |
| 5   |      |     |      |       |     |
| 6   |      |     |      |       |     |
| 7   |      |     |      |       |     |
| 8   |      |     |      |       |     |
| 9   |      |     |      |       |     |
| 10  | 7.65 | 140 | 0.82 |       | Y   |
| 11  |      |     |      |       |     |
| 12  |      |     |      |       |     |
| 13  |      |     |      |       |     |
| 14  |      |     |      |       |     |
| 15  |      |     |      |       |     |
| 16  |      |     |      |       |     |
| 17  |      |     |      |       |     |
| 18  | 7.60 | 140 | 0.85 |       | Y   |
| 19  |      |     |      |       |     |
| 20  |      |     |      |       |     |
| 21  |      |     |      |       |     |
| 22  |      |     |      |       |     |
| 23  |      |     |      |       |     |
| 24  | 7.56 | 140 | 0.85 |       | Y   |
| 25  |      |     |      |       |     |
| 26  |      |     |      |       |     |
| 27  |      |     |      |       |     |
| 28  |      |     |      |       |     |
| 29  |      |     |      |       |     |
| 30  |      |     |      |       |     |
| 31  |      |     |      |       |     |

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: June - 2024  
Month/Year

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

|       |   |                  |
|-------|---|------------------|
| pH    | <span style="border: 1px solid black; padding: 2px;">7.2</span> |                  |
| Alk   | <span style="border: 1px solid black; padding: 2px;">99</span>  | (Alkalinity)     |
| PO4   | <span style="border: 1px solid black; padding: 2px;">0.8</span> | (Orthophosphate) |
| Other | /   | (_____)          |

Print Name: Patricio Vargas Pino

Signature: *Patricio Vargas Pino*

Date: 07-08-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0