

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1	7.66	140	1.05		Y	minimums been met for
2						this day? PWS ID: 41 9 1 1 6 7
3						System Name: Mt. Hood Meadows Spring
4						Entry Point: A
5						Sample Period: July - 2024
6 7						Month/Year
8						Number of excursions* during this month:
9	7.52	120	1.25		Y	(Count the number of days when any WQP was
10	V					less than the minimum required)
11						
12						Total excursions during the previous 5 months: Q
13						(Over 9 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative)
15						For OHA use only
16	7.60	120	1.20		4	
17						Minimum Water Quality
18						Parameters as set by
19						pH 7.2
20						Alk 99 (Alkalinity)
21						PO4 0.8 (Orthophosphate)
22						Other ()
23 24	-7 1 -1	120	1.12		y	
25	7.67	140	WIL,		7	
26						
27						Datain Danie 2
28			·			Print Name: Tarrico Kamos rivo
29						Signature: Jahun format Date: 8/8/24
30						
31	7.64	120	112		Y	Send to DWP within 10 days after end of sampling period
lo = N = Excursion) Total N's						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/