

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4					
5	7.72	120	0.92		Y
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	7.80	120	0.89		Y
16					
17					
18					
19					
20					
21	7.81	120	1.02		Y
22					
23					
24					
25					
26	7.78	120	0.82		Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: August - 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="99"/>	(Alkalinity)
PO4	<input type="text" value="0.8"/>	(Orthophosphate)
Other	<input type="text" value="/"/>	()

Print Name: Patricio Ramos Pinedo

Signature: [Signature]

Date: 9/05/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's