

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4	7.80	120	0.82		Y
5					
6					
7					
8					
9					
10					
11	7.92	140	0.85		Y
12					
13					
14					
15					
16					
17					
18					
19	7.92	140	0.85		Y
20					
21					
22					
23					
24	7.90	140	0.89		Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: September - 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Patricio James Pineda

Signature: [Signature]

Date: 10-02-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's