

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1						minimums
2	7.88	120	0.85		Y	been met for this day? PWS ID: 41 9 1 1 6 7
3						System Name: Mt. Hood Meadows Spring
4						, 7
5						Entry Point: A
6						Sample Period: <u>Uctubre - 2024</u> Month/Year
7	7.58	120	0.85		Y	
8						Number of excursions* during this month:
9						(Count the number of days when any WQP was
10						less than the minimum required)
11						
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry
14	7.68	120	0.89		Y	Point and Distribution excursions are cumulative)
15						For OHA use only
16						
17		ļ				Minimum Water Quality
18						Parameters as set by
19						pH 7.2
20						Alk 99 (Alkalinity)
21						PO4 0.8 (Orthophosphate)
22	-9 ">		1 10		6.1	Other ()
23	7.63	120	1.12		4	
24			<u>:</u>			
25						
26						
27						Print Name: Katovuo Raymos Pino
28	770				. 1	Signature: gatur fame
29	7.79	120	1.18		Y	Date: 11-01-24
30						Send to DWP within 10 days after end of
31						sampling period
(No = N	o = N = Excursion) Total N's					

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/