

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4	7.85	120	1.12		Y
5					
6					
7					
8					
9					
10					
11	7.74	120	1.15		Y
12					
13					
14					
15					
16					
17					
18					
19					
20					
21	7.54	120	1.12		Y
22					
23					
24					
25					
26					
27	7.49	120	0.89		Y
28					
29					
30					
31					

(No = N = Excursion) Total N's 0

<<Have

minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: November - 2024  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH	<span style="border: 1px solid black; padding: 2px;">7.2</span>	
Alk	<span style="border: 1px solid black; padding: 2px;">99</span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;">0.8</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;">/</span>	( )

Print Name: Patricia Ramos Piro

Signature: 

Date: 12-10-24

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>