

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	<=Have ENTRY POINT
1						minums
2	7.3	100	0.99		Y	been met for this day? PWS ID: 41 9 1 1 6 7
3						System Name: Mt. Hood Meadows Spring
4						• 17
5						Entry Point: A
6						Sample Period: December - 2024
7						Month/Year
8						Number of excursions* during this month:
9	7.3	1.50	0.85		Y	(Count the number of days when any WQP was
10						less than the minimum required)
11						
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
14			•			
15						For OHA use only
16	7.4	120	1.12		Y	7 67 67 11 4 6 6 6 111 9
17						Winimum Water Quality
18						Parameters as set by
19						
20						pH 7.2
21						Alk 99 (Alkalinity)
22						PO4 0.8 (Orthophosphate)
23	7.47	140	0.82		4	Other ()
24						
25						
26						
27						Print Name: Patricia Rames Pino
28						
29	7.4b	140	0.99		Y	Signature: <u>fa four 4 court</u> Date: 01 - 04 - 2025
30						
31						Send to DWP within 10 days after end of
01				1		sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/