

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.78	140	0.89		Y
5					
6					
7					
8					
9					
10	7.70	140	0.82		Y
11					
12					
13					
14					
15					
16					
17	7.58	140	0.89		Y
18					
19					
20					
21					
22					
23					
24	7.38	140	0.99		Y
25					
26					
27					
28					
29					
30					
31					

(No = N = Excursion) Total N's **0**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **91167**

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: February - 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH **7.2**
Alk **99** (Alkalinity)
PO4 **0.8** (Orthophosphate)
Other **/** ()

Print Name: Patricio Ramos Piro

Signature: [Signature]

Date: 03-10-25

Send to DWP within 10 days after end of sampling period