

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рΗ	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1						minimums
2	7.40	140	0.95		Y	been met for this day? PWS ID: 41 9 1 6 7
3						System Name: Mt. Hood Meadows Spring
4						• 0
5						Entry Point: A Sample Period: March - 2025
6			-			Sample Period:
7		ļ				
8	ļ	1.55	0.00			Number of excursions* during this month: 0
9	7.36	120	0.92		4	(Count the number of days when any WQP was less than the minimum required)
10		-	-			less than the minimum required)
11	<u> </u>	 	-			Total assuming the provious 5 months (
12	ļ		-		•	Total excursions during the previous 5 months: (Over 9 excursions in 6 months is a violation. Entry
13	-		1.			Point and Distribution excursions are cumulative)
15						·
16	7 57	11:0	0.99		<u>.</u>	For OHA use only
17	1.52	140	0.19			
18		-				Minimum Water Quality
19						Parameters as set by
20						pH 7.2
21						Alk 99 (Alkalinity)
22						PO4 0.8 (Orthophosphate)
23	7.71	140	0.95		4	Other ()
24						
25		. :				
26						
27						Print Name: Patricio Ramos Rino
28	7.68	140	0.89		7	
29						Signature: fa fun formit Date: 4-8-2025
30						
31						Send to DWP within 10 days after end of sampling period
o = N	= Exc	ursion)	Total	N's	0	odinama konod

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/