

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <haye< th=""></haye<>
1						minimums ENTRY POINT
2						been met for this day? PWS ID: 41 9 1 1 6 7
3						System Name: Mt. Hood Meadows Spring
4	7.73	140	0.09		Y	
5	~- · · · · · · · · · · · · · · · · · · ·		_			Entry Point: A
6		-	-			Sample Period: Tone - 2025 Month/Year
7 8	J	-	-			
9		-				Number of excursions* during this month: 0
10	·	<u> </u>				(Count the number of days when any WQP was less than the minimum required)
11						rose alan aro minimani roquirou)
	7.72	120	0.82		V	Total excursions during the previous 5 months:
13	1316	120	0.02		-	(Over 9 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative)
15						Fan Olla was sub-
16			1,			For OHA use only
17 -	7.82	120	0.82		Y	Minimum Water Quality
18						Parameters as set by
19						
20						pH 7.2
21						Alk 99 (Alkalinity)
22						PO4 0.8 (Orthophosphate) Other ()
23 24 7	77	100	000		J	Other
25	73	120	0.82		Y	
26						
27						
28						Print Name: Tatricio, Lamos Pino
29						Signature: Janua Januar
30	_				-	Date: 7-10=125
_						Send to DWP within 10 days after end of
= N =	Excu	rsion)	Total I	v's C		sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/