

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				/	
2	7.60	100	0.92		Y
3					
4					
5					
6					
7					
8	7.80	120	0.99		Y
9					
10					
11					
12					
13					
14					
15	7.67	120	1.05		Y
16					
17					
18					
19					
20					
21					
22					
23					
24	7.52	120	0.99		Y
25					
26					
27					
28					
29					
30	7.68	120	1.08		Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: July - 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	()

Print Name: Patricio Ramos Pind
Signature: [Signature]
Date: 08-08-2025

Send to DWP within 10 days after end of
sampling period