

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4					
5					
6	7.37	120	0.85		Y
7					
8					
9					
10					
11					
12					
13					
14	7.38	120	1.12		Y
15					
16					
17					
18					
19	7.41	120	1.18		Y
20					
21					
22					
23					
24					
25					
26	7.63	120	1.02		Y
27					
28					
29					
30					
31					

(No = N = Excursion) Total N's **0**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: August - 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2

Alk 99 (Alkalinity)

PO4 0.8 (Orthophosphate)

Other / ()

Print Name: Patricia Ramos Pino

Signature: Patricia Ramos Pino

Date: 9-09-2025

Send to DWP within 10 days after end of
sampling period