

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1		and the second second				minimums ENTRY POINT
2						been met for this day? PWS ID: 41 9 1 1 6 7
3	7.63	100	0.99		Y	uno day:
4						System Name: Mt. Hood Meadows Spring
5						Entry Point: A
6						Sample Period: September - 2025
7						`Month/Year
8						Number of excursions* during this month:
9						(Count the number of days when any WQP was
10	7.63	100	1.02		Y	less than the minimum required)
11						
12						Total excursions during the previous 5 months:
13						(Over 3 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative)
15						For OHA use only
16						
17	7.78	120	1.15		4	Minimum Water Quality
18						Parameters as set by
19						pH 7.2
20						Alk 99 (Alkalinity)
21						PO4 0.8 (Orthophosphate)
22						Other (Crimopriospriate)
23						Other
	7.7b	120	1.15		4	
25						
26						24.0
27						Print Name: Patricio Lamas Tino
28						Signature: fatur famt
29						Date: 10-07-25
30						Send to DWP within 10 days after end of
31	<u> </u>	<u> </u>	<u> </u>		0	sampling period
(No = N	N = Exc	ursion				

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/