

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3	7.72	140	1.02		Y
4					
5					
6					
7					
8					
9					
10	7.73	140	1.08		Y
11					
12					
13					
14					
15					
16					
17	7.65	120	1.08		Y
18					
19					
20					
21					
22					
23					
24	7.53	140	1.08		Y
25					
26					
27					
28					
29					
30					
31	7.35	120	0.99		Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: December 2025  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	( )

Print Name: Patricio Ramos Pino

Signature: *Patricio Ramos Pino*

Date: 01-07-26

Send to DWP within 10 days after end of sampling period