

Day	pH	Alk	Phos	Other	Y/N
1	7.32	120	1.25	/	Y
2					
3					
4					
5					
6					
7	7.33	120	1.12		Y
8					
9					
10					
11					
12					
13					
14	7.33	120	1.21		Y
15					
16					
17					
18					
19					
20					
21	7.46	140	0.95		Y
22					
23					
24					
25					
26					
27					
28	7.36	140	1.08		Y
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: January - 2026  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.2	
Alk	99	(Alkalinity)
PO4	0.8	(Orthophosphate)
Other	/	( )

Print Name: Patricio Ramos Pino

Signature: *Patricio Ramos Pino*

Date: 02-06-26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0