

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				/	
2					
3					
4					
5					
6					
7	7.39	140	1.05		Y
8					
9					
10					
11					
12					
13					
14	7.40	140	0.89		Y
15					
16					
17					
18					
19					
20					
21	7.43	140	0.89		Y
22					
23					
24					
25					
26					
27					
28	7.52	140	1.05		Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91167

System Name: Mt. Hood Meadows Spring

Entry Point: A

Sample Period: March - 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 99 (Alkalinity)

PO4 0.8 (Orthophosphate)

Other / ()

Print Name: Patricio Ramos Pino

Signature: *Patricio Ramos Pino*

Date: 4/4/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0