



Oregon Health Authority

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.33				Y
4					
5					
6					
7	7.30				Y
8					
9					
10	7.34				Y
11					
12					
13					
14	7.30				Y
15					
16					
17					
18	7.27				Y
19					
20					
21	7.31				Y
22					
23					
24	7.35				Y
25					
26					
27					
28	7.34				Y
29					
30					
31	7.29				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: January 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Don A Drascher

Signature: Don A. Drascher

Date: 2-2-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>