



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.54				Y
2					
3					
4					
5					
6	7.60				
7					
8					
9	7.57				Y
10					
11					
12	7.59				Y
13					
14					
15					
16	7.55				Y
17					
18					
19	7.51				
20					
21					
22					
23	7.45				Y
24					
25					
26	7.44				Y
27					
28					
29					
30	7.45				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 91211

System Name: Pacific High School

Entry Point: A

Sample Period: September 2022  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.2

Alk   (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 10-4-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>