



Day	pH	Alk	Phos	Other	Y/N
1					
2	7.30				Y
3					
4					
5	7.29				Y
6					
7					
8					
9	7.30				Y
10					
11					
12	7.33				Y
13					
14					
15					
16	7.30				Y
17					
18					
19	7.32				Y
20					
21					
22	7.33				Y
23					
24					
25					
26	7.32				Y
27					
28					
29					
30	7.34				Y
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91211

System Name: Pacific High School

Entry Point: A

Sample Period: December 2022  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.2

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Don A. Drescher

Signature: Don A. Drescher

Date: 1-3-23

Send to DWP within 10 days after end of sampling period