



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

RECEIVED

FEB 01 2023

Certification
Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.45				Y
4					
5					
6	7.44				Y
7					
8	7.41				Y
9					
10					
11					
12					
13	7.33				Y
14					
15					
16					
17	7.29				Y
18					
19					
20	7.32				Y
21					
22					
23	7.33				Y
24					
25					
26					
27	7.37				Y
28					
29					
30	7.38				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: January 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 2-1-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>