

Day	pH	Alk	Phos	Other	Y/N
1	7.43				Y
2					
3	7.45				Y
4					
5					
6	7.45				Y
7					
8					
9					
10	7.41				Y
11					
12					
13	7.37				Y
14					
15					
16					
17	7.32				Y
18					
19					
20	7.36				Y
21					
22					
23					
24	7.37				Y
25					
26					
27	7.35				Y
28					
29					
30					
31	7.45				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: March 2023  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

Minimum Water Quality Parameters as set by

pH  (Alkalinity)

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: Dan A Drescher

Signature: Dan A Drescher

Date: 4-3-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>