



Day	pH	Alk	Phos	Other	Y/N
1	7.40				Y
2					
3					
4	7.37				Y
5					
6					
7	7.40				Y
8					
9					
10					
11	7.42				Y
12					
13					
14	7.45				Y
15					
16					
17					
18	7.51				Y
19					
20					
21	7.52				Y
22					
23					
24					
25	7.50				Y
26					
27					
28	7.51				Y
29					
30					
31	7.61				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: August 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Dou A Draescher

Signature: Dou A Draescher

Date: 9-7-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's