



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.58				Y
2					
3					
4					
5	7.55				Y
6					
7					
8	7.51				Y
9					
10					
11	7.40				Y
12					
13					
14					
15	7.43				Y
16					
17					
18	7.38				Y
19					
20					
21					
22	7.33				Y
23					
24					
25	7.31				Y
26					
27					
28					
29	7.36				Y
30					
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 91211

System Name: Pacific High School

Entry Point: A

Sample Period: September 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Don A Drascher

Signature: Don A. Drascher

Date: 10-2-23

Send to DWP within 10 days after end of sampling period