



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.35				Y
2					
3	7.35				Y
4					
5					
6	7.31				Y
7					
8					
9	7.28				Y
10					
11					
12					
13	7.27				Y
14					
15					
16					
17	7.30				Y
18					
19					
20	7.29				Y
21					
22	7.31				Y
23					
24					
25					
26					
27	7.27				Y
28					
29					
30	7.28				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: November 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 12-4-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>