



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.43				Y
2	7.42				Y
3					
4					
5	7.53				Y
6					
7					
8					
9	7.60				Y
10					
11					
12	7.60				Y
13					
14					
15					
16	7.60				Y
17					
18					
19					
20	7.61				Y
21					
22					
23	7.62				Y
24					
25					
26					
27	7.61				Y
28					
29	7.57				Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 3-4-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>