

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.45				Y
4					
5					
6	7.35				Y
7					
8					
9	7.38				Y
10					
11					
12					
13	7.36				Y
14					
15					
16	7.41				
17					
18					
19					
20	7.33				Y
21					
22					
23	7.31				Y
24					
25					
26					
27	7.35				Y
28					
29					
30	7.38				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: September 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

(No = N = Excursion) Total N's

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 10-3-24

Send to DWP within 10 days after end of sampling period