

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.26				Y
2					
3					
4	7.27				Y
5					
6					
7					
8	7.27				Y
9					
10					
11					
12	7.34				Y
13					
14					
15	7.28				Y
16					
17					
18	7.30				Y
19					
20					
21					
22	7.34				Y
23					
24					
25	7.33				Y
26					
27					
28					
29	7.32				Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: November 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 12-3-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's