

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.34				Y
3					
4					
5					
6	7.31				Y
7					
8					
9	7.31				Y
10					
11					
12					
13	7.31				Y
14					
15					
16	7.33				Y
17					
18					
19					
20	7.34				Y
21					
22					
23	7.35				Y
24					
25					
26					
27	7.35				Y
28					
29	7.32				Y
30					
31	7.40				Y

<<Have minimums been met for this day? PWS ID: 41

System Name: Pacific High School

Entry Point: A

Sample Period: December 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 1-6-25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's