

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.35				Y
2					
3					
4	7.28				Y
5					
6					
7	7.30				Y
8					
9					
10					
11	7.31				Y
12					
13					
14	7.29				Y
15					
16					
17					
18					
19	7.32				Y
20					
21	7.30				Y
22					
23					
24					
25	7.26				Y
26					
27					
28	7.27				Y
29					
30	7.28				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

91211

System Name: Pacific High School

Entry Point: A

Sample Period: April 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH



Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 5-1-25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>