

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.32				Y
3					
4					
5					
6	7.34				Y
7					
8					
9	7.34				Y
10					
11					
12					
13	7.36				Y
14					
15					
16	7.38				Y
17					
18					
19					
20	7.39				Y
21					
22					
23	7.40				Y
24					
25					
26					
27	7.46				Y
28					
29					
30	7.45				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

9 1 2 1 1

System Name: Pacific High School

Entry Point: A

Sample Period: June 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other

(No = N = Excursion) Total N's 0

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 7-9-25

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>