

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.30				Y
2					
3					
4					
5	7.30				Y
6					
7					
8	7.30				Y
9					
10					
11					
12	7.31				Y
13					
14					
15	7.33				Y
16					
17					
18					
19	7.30				Y
20					
21					
22	7.31				Y
23					
24					
25					
26	7.29				Y
27					
28					
29	7.27				Y
30	7.25				Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 91211

System Name: Pacific High School

Entry Point: A

Sample Period: September 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	 	
Alk	 	(Alkalinity)
PO4	 	(Orthophosphate)
Other	 	()

Print Name: Don A Drescher

Signature: Don A. Drescher

Date: 10-1-25

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>