

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.27				Y
2					
3	7.29				Y
4					
5					
6	7.30				Y
7					
8					
9					
10	7.28				Y
11					
12					
13	7.30				Y
14					
15					
16					
17	7.29				Y
18					
19					
20	7.32				Y
21					
22					
23					
24	7.27				Y
25					
26					
27	7.30				Y
28					
29					
30					
31	7.32				Y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 91211

System Name: Pacific High School

Entry Point: A

Sample Period: October 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Don A. Drascher
Signature: Don A. Drascher
Date: 11-5-25

Send to DWP within 10 days after end of
sampling period