

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	6.7		1.0		Y
4					
5					
6	6.7		1.0		Y
7					
8					
9					
10	6.7		1.0		Y
11					
12					
13					
14	6.7		1.0		
15					
16					
17					
18	6.7		1.0		Y
19					
20	6.7		1.0		Y
21					
22					
23					
24	6.7		1.0		Y
25					
26					
27	6.7		1.0		Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

ENTRY POINT

EP-A

PWS ID 4191671

DIXIE ELEMENTARY SD 509J

Sample period: May 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Matt Holliday

Signature: [Signature]

Date & Phone#: 6/1/2021 541-606-2998

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0