

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	6.7		1.0		Y
2					
3					
4	6.7		1.0		Y
5					
6					
7					
8					
9	6.7		1.0		Y
10					
11	6.7		1.0		Y
12					
13					
14	6.7		1.0		Y
15					
16					
17	6.7		1.0		Y
18					
19					
20	6.7		1.0		Y
21					
22					
23					
24	6.7		1.0		Y
25					
26					
27					
28					
29	6.7		1.0		Y
30					
31					

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

ENTRY POINT

EP-A

PWS ID 4191671

DIXIE ELEMENTARY SD 509J

Sample period: June 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 6.7

PO4 1. (Orthophosphate)

Print Name: Matthew Holliday

Signature: [Signature]

Date & Phone#: 6/9/2021 541-602-2998

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0