

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2	6.8		1.0		Y
3					
4	6.7		1.0		Y
5					
6					
7					
8					
9	6.7		1.0		Y
10					
11					
12	6.7		1.0		Y
13					
14					
15					
16					
17	6.7		1.0		Y
18					
19					
20	6.7		1.0		Y
21					
22					
23					
24	6.7		1.0		Y
25					
26	6.7		1.0		Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4191671**

**DIXIE ELEMENTARY SD 509J**

Sample period: August 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

PO4  (Orthophosphate)

Print Name: Math Holliday

Signature: [Signature]

Date & Phone#: 9/8/2021 541-602-2998

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's