

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	6.7		1.0		Y
6					
7	6.7		1.0		Y
8					
9					
10	6.7		1.0		Y
11					
12	6.7		1.0		Y
13					
14					
15					
16					
17					
18					
19	6.8		1.0		Y
20					
21	6.7		1.0		Y
22					
23					
24	6.7		1.0		Y
25					
26					
27	6.7		1.0		Y
28					
29					
30					
31	6.7		1.0		Y

(No = N = Excursion) **Total N's** 0

<<Have  
minimums  
been met for  
this day?

County: Linn

Agency: LINN COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4191671**

**DIXIE ELEMENTARY SD 509J**

Sample period: January 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

**Reference**

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 6.7

PO4 1. (Orthophosphate)

Print Name: Matt Holliday

Signature: [Signature]

Date & Phone#: 1/31/2022 541-602-2998

Send to DWP within 10 days after end of  
sampling period