

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	6.7		1.0		
2					
3					
4	6.7		1.0		
5					
6					
7	6.7		1.0		
8					
9	6.7		1.0		
10					
11					
12					
13					
14					
15					
16	6.7		1.0		
17					
18	6.7		1.0		
19					
20					
21	6.7		1.0		
22					
23					
24					
25	6.7		1.0		
26					
27					
28					
29	6.7		1.0		
30					
31	6.7		1.0		

<<Have
minimums
been met for
this day?

County: Linn

Agency: LINN COUNTY

ENTRY POINT

EP-A

PWS ID 4191671

DIXIE ELEMENTARY SD 509J

Sample period: March 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 6.7

PO4 1. (Orthophosphate)

Print Name: Matt Holliday

Signature: Matt Holliday

Date & Phone#: 4/8/2022 541-602-2998

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0