

Day	pH	Alk	Phos	Other	Y/N
1					
2	6.8	-	0.8	SEE Note 1	N
3	6.8	-	0.7	SEE Note 1	N
4					
5					
6	6.8	-	0.9	SEE Note 1	N
7					
8	6.8	-	0.9	SEE Note 1	N
9					
10	6.8	-	1.0	SEE Note 1	Y
11					
12					
13	6.8	-	1.0	SEE Note 1	Y
14					
15	6.8	-	0.9	SEE Note 1	N
16	6.8	-	1.0	SEE Note 1	Y
17					
18					
19					
20	6.8	-	1.0	SEE Note 1	Y
21					
22					
23	6.8	-	1.0	SEE Note 1	Y
24	6.8	-	1.0	SEE Note 1	Y
25	6.8	-	1.0	SEE Note 1	Y
26					
27	6.8		1.0	SEE Note 1	Y
28					
29	6.8		1.0	SEE Note 1	Y
30					
31	6.8		1.0	SEE Note 1	Y

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4191671**

**DIXIE ELEMENTARY SD 509J**

Sample period: March 2023  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Note 1: PH approximated w/ Pentair "Pool & Spa Test Kit" (RAINBOW)

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

PO4  (Orthophosphate)

Print Name: Mike Ruark  
 Signature: Michael Ruark  
 Date & Phone#: 3/31/2023 (541) 602-2775

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's