

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	6.8	-	1.0	SEE Note 1	Y
4					
5	6.77	-	1.0	See Note 2	Y
6					
7	6.78	-	1.0		Y
8					
9					
10	6.86	-	1.0		Y
11					
12	6.76	-	0.8		N
13					
14	6.70	-	~0.9		N
15					
16					
17					
18	6.76	-	1.0		Y
19	6.74	-	1.0		Y
20					
21	6.73	-	1.0		Y
22					
23					
24	6.83	-	1.0		Y
25					
26	6.70	-	1.0		Y
27					
28	6.71	-	1.0		Y
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91671

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: April 2023  
Month/Year

Number of excursions\* during this month: 2  
 (Count the number of days when any WQP was less than the minimum required)  
 Note 1: pH approximated w/Pentair Pool + Spa "Rainbow" test kit

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by STATE:**

pH	6.7	
Alk		(Alkalinity)
PO4	1.	(Orthophosphate)
Other		(_____)

Note 2: Return to use of YSI Ecosense PH100A (PH/temp probe & meter)

Print Name: Mike Ruark

Signature: Michael Ruark

Date: 5/02/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 2