

Day	pH	Alk	Phos	Other	Y/N
1	6.7	-	1.0		Y
2					
3	6.80		1.0	SEE Note 1	Y
4					
5	6.70		1.0		Y
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	6.71	-	1.0		Y
16					
17	6.7	-	1.0		Y
18					
19	6.7	-	1.0		Y
20					
21					
22					
23	6.71	-	1.0		Y
24	6.71	-	1.0		Y
25					
26	6.71	-	1.0		Y
27					
28					
29					
30	6.73	-	1.0		Y
31	6.72	-	1.0		Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: MAY 2023
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)
 Note: Probe re-calibrated

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by STATE:

pH	<input type="text" value="6.7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1."/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Mike Ruark
 Signature: Michael Ruark
 Date: 5/31/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's