

| Day | pH   | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1   |      |     |      |       |     |
| 2   | 6.73 |     | 1.0  |       | Y   |
| 3   |      |     |      |       |     |
| 4   |      |     |      |       |     |
| 5   | 6.74 |     | 1.0  |       | Y   |
| 6   | 6.6  |     | ≈1.5 |       | N   |
| 7   | 6.7  |     | ≈1.5 |       | Y   |
| 8   | 6.7  |     | ≈1.5 |       | Y   |
| 9   | 6.7  |     | ≈1.5 |       | Y   |
| 10  |      |     |      |       |     |
| 11  |      |     |      |       |     |
| 12  | 6.64 |     | ≈1.5 |       | N   |
| 13  | 6.62 |     | 1.0  |       | N   |
| 14  | 6.7  |     | 1.0  |       | Y   |
| 15  | 6.7  |     | 1.0  |       | Y   |
| 16  | 6.71 |     | 1.0  |       | Y   |
| 17  |      |     |      |       |     |
| 18  |      |     |      |       |     |
| 19  |      |     |      |       |     |
| 20  | 6.7  |     | 1.0  |       | Y   |
| 21  | 6.7  |     | 1.0  |       | Y   |
| 22  | 6.7  |     | 1.0  |       | Y   |
| 23  |      |     |      |       |     |
| 24  |      |     |      |       |     |
| 25  |      |     |      |       |     |
| 26  |      |     |      |       |     |
| 27  | 6.7  |     | 1.0  |       | Y   |
| 28  | 6.7  |     | 1.0  |       | Y   |
| 29  | 6.7  |     | 1.0  |       | Y   |
| 30  |      |     |      |       |     |
| 31  |      |     |      |       |     |

(No = N = Excursion) Total N's **3**

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: DIXIE ELEMENTARY SD 509J

Entry Point: EP-A

Sample Period: June 2023  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by STATE:**

|       |                                  |                  |
|-------|----------------------------------|------------------|
| pH    | <input type="text" value="6.7"/> |                  |
| Alk   | <input type="text"/>             | (Alkalinity)     |
| PO4   | <input type="text" value="1."/>  | (Orthophosphate) |
| Other | <input type="text"/>             | (_____)          |

Print Name: Mike Roark

Signature: Michael Roark

Date: 6/29/2023

Send to DWP within 10 days after end of sampling period